

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016140  
DATE: 04/24/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: VALDA 90  
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>VALDA 90 OOD</b> <b>5002 Western Industrial Zone</b> <b>Veliko Tarnovo, Bulgaria</b>	<b>Series "ML8 Awning Window"</b> <b>Aluminum Awning Window</b>  Configuration: X Glazing: Insulating Glass (Tempered)  Frame: W-1499mm(59")      H-908mm(35.75") Vent: W-1445mm(56.88")      H-899mm(35.38") DLO: W-1197mm(47.13")      H-602mm(23.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG100 1499 x 908 (59 x 36)-AP</b> <b>Design Pressure: ±4800 Pa (±100 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC  
Report No: M7166.01-301-44  
Expiration Date: **March 31, 2028**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023