

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016143  
DATE: 04/24/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: VALDA 90  
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>VALDA 90 OOD</b> <b>5002 Western Industrial Zone</b> <b>Veliko Tarnovo, Bulgaria</b>	<b>Series "CS 38"</b> <b>Aluminum Glazed Outswing</b> <b>Side Hinged Door</b> <b>(Low Sill)</b> Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.25") H-2400mm(94.50") Panel: W-1114mm(43.88") H-2354mm(92.69") DLO: W-949mm(37.38") H-2189mm(86.19")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class CW-PG40 1200 x 2400 (47 x 95)-SHD</b> <b>Design Pressure: ±1920 Pa (±40 psf)</b> Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC  
Report No: E5360.02-301-44  
Expiration Date: **March 31, 2028**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.D.' or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)