

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016144.02
DATE: 04/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VALDA 90
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VALDA 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "CS 68" Aluminum Glazed Inswing Side Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1202mm(47.31") H-2430mm(95.69") Panel: W-1105mm(43.50") H-2335mm(91.94")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG20 1202 x 2430 (47 x 96)-SHD Design Pressure: 960 Pa (20 psf) Positive Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: E1242.02-301-11
Expiration Date: March 31, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com