

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016147  
DATE: 04/24/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: VALDA 90  
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>VALDA 90 OOD</b><br><b>5002 Western Industrial Zone</b><br><b>Veliko Tarnovo, Bulgaria</b> | <b>Series "CS68"</b><br><b>Aluminum Fixed Window</b><br><br>Configuration: O<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1524mm(60") H-2515mm(99") |

| SPECIFICATION                          | PRODUCT RATING   |
|--|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> | <b>Class AW-PG75 1524 x 2515 (60 x 99)-FW</b><br><b>Design Pressure: ±3600 Pa (±75 psf)</b><br>Water Penetration Resistance Test Pressure: 730 Pa (15.20 psf)<br>Canadian Air Infiltration/Exfiltration Level: Fixed |

Product Tested By: Canadian Building Envelope Science and Technology  
Report No: L15-878-3442aR2  
Expiration Date: **March 31, 2028**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)