

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016151
DATE: 04/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VALDA 90
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VALDA 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "HFP 147 HiFinity" Aluminum Sliding Glass Door Configuration: XO Glazing: Insulating Glass - Double Laminated Glass (Annealed) Frame: W-4836mm(190.40") H-3472mm(136.70") Panel: W-2370mm(93.30") H-3327mm(131")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG15 4836 x 3472 (190 x 137)-SD Design Pressure: ±720 Pa (±15 psf) Water Penetration Resistance Test Pressure: 140 Pa (2.86 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Canadian Building Envelope Science and Technology
Report No: L14-878-3954aR1
Expiration Date: March 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi", is written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com