

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016153
DATE: 04/25/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VALDA 90
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VALDA 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "Reynaers CT20_166" Aluminum Glazed Window Wall Configuration: OOO/OOO Glazing: Insulating Glass (Tempered) Frame: W-3776mm(148.66") H-6647mm(261.69") Panel: W-1239mm(48.79") H-3050mm(120.08") DLO: W-1124mm(44.27") H-2948mm(116.06")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/12 ASTM E330-14 ASTM E331-00	Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf)

Product Tested By: UL Laboratory Canada, Inc.
Report No: AC-00433-A
Expiration Date: March 31, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com