

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI016154</u>
DATE:	<u>04/25/2024</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>Fleetwood</u>
CODE:	<u>1855-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Fleetwood Windows and Doors</p> <p>1 Fleetwood Way</p> <p>Corona, CA 92879</p>	<p style="text-align: center;">Series “EDGE s ”</p> <p style="text-align: center;">Aluminum Sliding Glass Door</p> <p style="text-align: center;">(w/7/8" Sill Riser)</p> <p style="text-align: center;">Configuration: XXX</p> <p style="text-align: center;">Glazing: IG-Ext. 1/4" Tempered Glass/Int. 1/4" Heat Strengthened Glass/0.090" SentryGlas Interlayer/1/4" Heat Strengthened Glass</p> <p style="text-align: center;">or</p> <p style="text-align: center;">1/4" Heat Strengthened Glass/0.090" SentryGlas Interlayer/1/4" Heat Strengthened Glass</p> <p>Frame: W-4570mm(179.94") H-3048mm(120")</p> <p>Panel: W-1529mm(60.19") H-2942mm(115.81")</p> <p>DLO: W-1478mm(58.19) H-2881mm(113.44")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">AAMA/WDMA/CSA 101/I.S.2/A440-17</p> <p style="text-align: center;">ASTM E1886-13a</p> <p style="text-align: center;">ASTM E1996-14a</p> <p style="text-align: center;">TAS 201/202/203-94</p>	<p style="text-align: center;">Class LC-PG75 4570 x 3048 (180 x 120)-SD</p> <p style="text-align: center;">Design Pressure: ±3600 Pa (±75 psf)</p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 540 Pa (11.25 psf)</p> <p style="text-align: center;">Missile Level D - Wind Zone 4</p> <p style="text-align: center;">Large Missile Impact Rated</p>

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: TEL 01993774/TEL 01993775/TEL 01993776
 Expiration Date: **October 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/Email: nami@namiinc.com