# **NOTICE OF PRODUCT CERTIFICATION**



<b>CERTIFICATION NO:</b>		
DATE:		
<b>CERTIFICATION PROGRAM:</b>	ł	Cl
<b>COMPANY:</b>		
CODE:		
<b>EXPIRATION DATE:</b>		

FIGHTION

NI016162	
04/29/2024	
Fire	
<b>ESI Interiors</b>	
3037-1	
04/30/2028	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ESI Interiors Corporation</b>	Steve's & Sons/Crest Doors
12336 West Overland Drive	<b>Two-Panel Wood Skin</b>
Boise, ID 83709	Side-Hinged Door Assembly
	Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing Only
	Single Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"
SPECIFICATION	PRODUCT RATING

UL 10C (2021)

#### **PRODUCT RATING**

20 Minute-Positive Pressure w/o Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

## **TEST REPORT**

### Intertek Test Report No: 105581831MID-004R1

Administrator's Signature:

# NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023