## NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO: NI016163** 

**DATE:** 04/29/2024

CERTIFICATION PROGRAM: Fire

**COMPANY:** ESI Interiors

**CODE:** <u>3037-1</u>

**EXPIRATION DATE: 04/30/2028** 

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="https://www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ESI Interiors Corporation	20 Minute Category C
12336 West Overland Drive	Proprietary Wood Door Frames
Boise, ID 83709	
	Manufacture Specific Fire Door Frames for Single and Double Swing Installation in 20 Minute Locations
	Single Door Maximum Size: 4'0" x 9'0" Double Door Maximum Size: 8'0" x 9'0"
	Minimum Thickness: 3-3/4"

UL 10C (1998) UBC Standard 7-2 (1997) 20 Minute-With & Without Hose Stream Positive Pressure	SPECIFICATION	PRODUCT RATING
, ,	UL 10C (1998)	20 Minute-With & Without Hose Stream
**************************************	<b>UBC Standard 7-2 (1997)</b>	Positive Pressure
UBC Standard 7-2 (1994) Category C- Proprietary Frame	<b>UBC Standard 7-2 (1994)</b>	Category C- Proprietary Frame

## **TEST REPORT**

Warnock Hersey Test Report No: WHI-495-0509
Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460
Priest & Assoc. Engineering Evaluation No: 10260
NAMI Waiver of Retest: W-1747

Administrator's Signature:

NATIONAL ACCREDITATION AND

MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com

NOPC 03/30/2023