

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016172
DATE: 04/29/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Steves and Sons Corporation 203 Humble Avenue San Antonio, TX 78225	Series "Palisades" Glazed Outswing Fiberglass Side-Hinged Doors (Impact Rated) Configuration: XX Glazing: IG-Ext. 1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass/Int. 1/8" Tempered Glass Frame: W-1880mm(74") H-2475mm(96.75") Panel: W-908mm(35.75") H-2413mm(95") DLO: W-530mm(20.88") H-2004mm(78.88")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00 ASTM E1886-13a/ASTM E1996-14a	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01523780
Expiration Date: November 30, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com