

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015870
DATE: 09/07/2023
CERTIFICATION PROGRAM: Structural
COMPANY: ABI Windows
CODE: 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ABI Windows, LLC 1121 Fulwiler Road Abilene, Texas 79603	Series "500" Vinyl Single Hung Window (w/Small/Large Weep) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.50") H-2121mm(83.50") Sash: W-1130mm(44.50") H-1041mm(41") DLO: W-1114mm(43.88") H-975mm(38.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 1207 x 2121 (48 x 84)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2602T0001
Expiration Date: July 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com