

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016177
DATE: 05/07/2024
CERTIFICATION PROGRAM: Fire
COMPANY: SOCO Door
CODE: 3050-1
EXPIRATION DATE: 05/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Soco Door & Window Services, LLC. 2928 North 35th Ave, Suite 4 Phoenix, AZ 85017	Rogue Valley's 20 Minute 4-13/16" Wood Frame w/Hose Stream Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations Maximum Frame Size: 84" x 96" Minimum Width: 4-13/16" Nominal Thickness: 9/16"

SPECIFICATION	PRODUCT RATING
UBC 7-2 (1997) NFPA 252 (2008) UL 10(c) (2001)(2009) UL 10 (b) (2008)(2009) CAN4 S104 (1980(R1985))(2010)	20 Minute-With Hose Stream Positive Pressure/Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No: 3049231

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023

