

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016183  
**DATE:** 05/13/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Passive  
**CODE:** 3052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Shandong New Passive System Windows &amp; Doors Company, Ltd.</b> <b>No. 7027, Dongtai Road, Dongcheng Street, Linqu County, Weifang City, Shandong Province, China 262600</b>	<b>Series "OW75"</b> <b>Aluminum Awning Window</b>  Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1500mm(59.06") H-900mm(35.43") Sash: W-1436mm(56.54") H-836mm(32.91") DLO: W-1316mm(51.81") H-716mm(28.19")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG50 1500 x 900 (59 x 35)-AP</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11psf)</b>

Product Tested By: Intertek Testing Services Shenzhen Ltd.  
Report No: 231115006SHF-001  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi", is written over the signature line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023