

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016184
DATE: 05/13/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Passive
CODE: 3052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shandong New Passive System Windows & Doors Company, Ltd. No. 7027, Dongtai Road, Dongcheng Street, Linqu County, Weifang City, Shandong Province, China 262600	Series "OW75" Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-900mm(35.43") H-1500mm(59.06") Sash: W-836mm(32.91") H-1436mm(56.54") DLO: W-716mm(28.19") H-1316mm(51.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 900 x 1500 (35 x 59)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 231115006SHF-002
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023