

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016186
DATE: 05/13/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Passive
CODE: 3052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shandong New Passive System Windows & Doors Company, Ltd. No. 7027, Dongtai Road, Dongcheng Street, Linqu County, Weifang City, Shandong Province, China 262600	Series "W75H" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1500mm(59.06") H-2500mm(98.43") DLO: W-1391mm(54.76") H-2391mm(94.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 1500 x 2500 (59 x 98)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 231115006SHF-006
Expiration Date: December 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023