

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016187.01
DATE: 05/13/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Passive
CODE: 3052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shandong New Passive System Windows & Doors Company, Ltd. No. 7027, Dongtai Road, Dongcheng Street, Linqu County, Weifang City, Shandong Province, China 262600	Series "PS150" Aluminum Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-3100mm(122.05") H-2400mm(94.49") Panel: W-1491mm(58.70") H-2311mm(90.98") DLO: W-1354mm(53.31") H-2174mm(85.59")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class AW-PG40 3100 x 2400 (122 x 94)-SD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 240307006SHF-001
Expiration Date: March 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023