

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016188
DATE: 05/13/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Passive
CODE: 3052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shandong New Passive System Windows & Doors Company, Ltd. No. 7027, Dongtai Road, Dongcheng Street, Linqu County, Weifang City, Shandong Province, China 262600	Series "OD75F" Aluminum Side-Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-2400mm(94.49") Panel: W-1092mm(42.99") H-2327mm(91.61") DLO: W-932mm(36.69") H-2167mm(85.31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG30 1200 x 2400 (47 x 94)-SHD Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 231115006SHF-004
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023