

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016203
DATE: 05/28/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Altitude
CODE: 2989-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Altitude Windows 901 Travis Road Mission, TX 78572 | Series "Altitude 9600 Classic PW" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1524mm(60") DLO: W-1453mm(57.19") H-1453mm(57.19") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class LC-PG30 1524 x 1524 (60 x 60)-FW Design Pressure: 1440 Pa (30 psf) Positive Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 1680 Pa (35 psf) Water Penetration Resistance Pressure: 580 Pa (12.12 psf) Canadian Air Infiltration/Exfiltration Level: Fixed |

Product Tested By: Intertek, PLC
Report No: K7577.04-501-44
Expiration Date: May 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023