

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016227
DATE: 06/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Shandong Huada
CODE: 3057-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shandong Huada Window-Door & Curtain Wall Co., Ltd. 369 Yuzhong Road, Linqu County, Weifang, Shandong, China 262600	Series "GWTZB80" Aluminum Dual Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1800mm(70.87") Sash: W-1163mm(45.79") H-1763mm(69.41") DLO: W-1072mm(42.20") H-1672mm(65.83")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG50 1200 x 1800 (47 x 71)-DAW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek - Shanghai
Report No: 230714017SHF-001
Expiration Date: August 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com