

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016239
DATE: 06/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Banglimang
CODE: 3064-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shanghai Banglimang New Energy Materials Co., Ltd. No. 6 Industrial Incubation Park, Xingang Town, Lianxi District, Jiujiang City, Jiangxi, China 332000	Series "PN65" PNOC-CW Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-800mm(31.50") H-1500mm(59.06") Vent: W-746mm(29.37") H-1446mm(56.93") DLO: W-606mm(23.86") H-1306mm(51.42")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG40 800 x 1500 (32 x 59)-C Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek, PLC
Report No: 221229004SHF-001
Expiration Date: **February 28, 2027**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023