

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016240
DATE: 06/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Banglimang
CODE: 3064-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shanghai Banglimang New Energy Materials Co., Ltd. No. 6 Industrial Incubation Park, Xingang Town, Lianxi District, Jiujiang City, Jiangxi, China 332000	Series "PN65" PNOC-TTW Aluminum Dual Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1800mm(70.87") Vent: W-1146mm(45.12") H-1746mm(68.74") DLO: W-1036mm(40.79") H-1636mm(64.41")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG40 1200 x 1800 (47 x 71)-DAW Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Intertek, PLC
Report No: 240307010SHF-001
Expiration Date: **March 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023