

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016198
DATE: 05/21/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Multi Side
CODE: 3018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Multi Side Mill Supply, LLC 2505 Viceroy Drive, Unit C Winston-Salem, NC 27103	Series "Salamander Green Evolution" Vinyl Tilt & Turn Window (w/ Fixed Window) Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-2600mm(102.38") H-1800mm(70.88") Sash: W-1149mm(45.24") H-1724mm(67.87") DLO: W-1285mm(50.59") H-1660mm(65.35")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG35 2600 x 1800 (102 x 71)-DAW Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 220 Pa (5.43 psf)

Product Tested By: Blackwater Testing, SRL
Report No: BW-MUL-24-001
Expiration Date: April 30, 2028

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023