

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016244
DATE: 07/10/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Warren
CODE: 2890-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Warren Windows & Doors (GuangDong) Co., Ltd. 7 East Industrial Road, Songxia Ind. Park Guangdong, China 528200	Series "Slim" Aluminum Lift & Slideing Door Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-2438mm(96") H-2144mm(84.39") Panel: W-1183mm(46.58") H-2063mm(81.2") DLO: W-1108mm(43.63") H-1923mm(75.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG30 2438×2144 (96×84)-SD Design Pressure: ±1436 Pa (±30psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: Intertek, PLC
Report No: 230630014SHF-003
Expiration Date: August 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023