

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016245  
**DATE:** 07/10/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Warren  
**CODE:** 2890-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Warren Windows &amp; Doors</b><br><b>(GuangDong) Co., Ltd.</b><br><b>7 East Industrial Road, Songxia Ind. Park</b><br><b>Guangdong, China 528200</b> | <b>Series "Slim"</b><br><b>Aluminum Tilt &amp; Turn Window</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1219mm(48") H-1829mm(72")<br>Panel: W-1178mm(46.39") H-1788mm(70.39")<br>DLO: W-1104mm(43.47") H-1714mm(67.47") |

| SPECIFICATION                          | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> | <b>Class CW-PG30 1219×1829 (48×72)-DAW</b><br><b>Design Pressure: ±1436 Pa (±30psf)</b><br><b>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)</b> |

Product Tested By: Intertek, PLC  
Report No: 230630014SHF-002  
Expiration Date: August 31, 2027

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023