

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016260.01
DATE: 07/16/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VIG Windows
CODE: 3059-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VIG Windows (Shandong) Co., Ltd. No. 304 Foguang Road, Taishan District, Taian, Shandong, China 271000	Series "VWP91-Awning Window" Aluminum Awning Window Configuration: X Frame: W-1200mm(47.24") H-1000mm(39.37") Sash: W-1149mm(45.24") H-949mm(37.36") DLO: W-1002mm(39.45") H-802mm(31.57")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG50 1200 x 1000 (47 x 39)-AP Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: 230906006SHF-006
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com