

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016260  
DATE: 07/16/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: VIG Windows  
CODE: 3059-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>VIG Windows (Shandong) Co., Ltd.</b> <b>No. 304 Foguang Road, Taishan District,</b> <b>Taian, Shandong, China 271000</b>	<b>Series "VWS70-Awning Window"</b> <b>Aluminum Awning Window</b>  Configuration: X  Frame: W-1200mm(47.24") H-1000mm(39.37") Sash: W-1134mm(44.65") H-934mm(36.77") DLO: W-987mm(38.86") H-787mm(30.98")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>CSA A440S1-19</b>	<b>Class CW-PG50 1200 x 1000 (47 x 39)-AP</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC  
Report No: 230906006SHF-005  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)