

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016264.01  
**DATE:** 07/16/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** VIG Windows  
**CODE:** 3059-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>VIG Windows (Shandong) Co., Ltd.</b> <b>No. 304 Foguang Road, Taishan District,</b> <b>Taian, Shandong, China 271000</b>	<b>Series “VWP91-Fixed Window”</b> <b>Aluminum Fixed Window</b>  Configuration: O  Frame: W-1500mm(59.06") H-2500mm(98.43") DLO: W-1424mm(56.06") H-2424mm(95.43")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>CSA A440S1-19</b>	<b>Class CW-PG60 1500 x 2500 (59 x 98)-FW</b> <b>Design Pressure: ±2880 Pa (±60 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC  
Report No: 230906006SHF-002  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)