NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016297.09
DATE: 07/31/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation **1750 Indian Wood Circle** **Maumee, OH 43537**	**Series "Veris"** **Aluminum Outswing Glazed** **Pivot Door** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1218mm(47.97") H-2547mm(100.28") Panel: W-1092mm(43") H-2438mm(96") DLO: W-895mm(35.25") H-2267mm(89.25")

SPECIFICATION	PRODUCT RATING
TAS 202-94 (Structural Only) **ASTM E330-14**	**Design Pressure: ±2400 Pa (±50 psf)**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01463794/TEL01463795/W-2126
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com