

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016293.01
DATE: 08/29/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Domadeco
CODE: 2704-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Domadeco, Inc. 7455 Arroyo Crossing, Suite 220 Las Vegas, NV 89113	Series "Outswing Door" Aluminum Glazed Outswing Side Hinged Door Configuration: X Glazing: Insulating Glass 5/32" Annealed Glass/0.090" Eastman Chemical PVB Storm Interlayer/5/32" Annealed Glass/3/16" Annealed Glass/5/32" Annealed Glass/0.090" Eastman Chemical PVB Storm Interlayer/5/32" Annealed Glass Frame: W-1070mm(42.11") H-2438mm(98") Panel: W-961mm(37.82") H-2352mm(92.59") DLO: W-772mm(30.38") H-2152mm(84.72")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM E1886-19 ASTM E1996-23 ASTM E283-19/ASTM E331-00/23	Design Pressure: +65/-70 psf Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf) Missile Level D Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-DOM-24-001/W-2127
Expiration Date: May 31, 2028

A handwritten signature in black ink, appearing to be "Shelby".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023