

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016304  
**DATE:** 08/12/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Multi Side  
**CODE:** 3018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Multi Side Mill Supply, LLC</b> <b>2505 Viceroy Drive, Unit C</b> <b>Winston-Salem, NC 27103</b>	<b>Series "Salamander Green Evolution 76MD"</b> <b>Vinyl Outswing Side Hinged Door</b>  Configuration: X Glazing: Insulating Glass (Tempered)  Frame: W-905mm(35.63") H-2127mm(83.75") Panel: W-832mm(32.75") H-2083mm(82") DLO: W-603mm(23.75") H-1727mm(68")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b>	<b>Class LC-PG45 905 x 2127 (36 x 84)-SHD LW</b> <b>Design Pressure: ±2160 Pa (±45 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)</b>

Product Tested By: Molimo, LLC  
Report No: 28222.01-106-11  
Expiration Date: **June 30, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023