

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016314
DATE: 08/26/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Truitt & White
CODE: 2807-1
EXPIRATION DATE: 08/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Truitt & White Lumber Company, Inc. 642 Hearst Avenue Berkeley, CA 94710	TruStile 20-Minute MDF/Wood Side Hinged Door Manufacture Specific Fire Door for Single Swing Installation in 20-Minute Locations Single Door Maximum Size: 3'0" x 8'0"

SPECIFICATION	PRODUCT RATING
CAN / ULC S104 (2015 (R2020)) UL 10C (2016) UL 10B (2015) NFPA 252 (2017)	20-Minute Positive Pressure With or Without Hose Stream Category A - No Additional Edge-Sealing Required

TEST REPORT
Intertek Test Report No(s): 3132967COQ-005, 3144820COQ-002

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023