

# NOTICE OF PRODUCT CERTIFICATION



<b>CERTIFICATION NO:</b>	<u>NI016333.01</u>
<b>DATE:</b>	<u>09/17/2024</u>
<b>CERTIFICATION PROGRAM:</b>	<u>Structural</u>
<b>COMPANY:</b>	<u>Win-Curve</u>
<b>CODE:</b>	<u>3079-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>Win-Curve Windows, LLC</b></p> <p><b>2525 North Center Street</b></p> <p><b>Bonham, Texas 75418</b></p>	<p><b>Series "WCW 713-PDXO"</b></p> <p><b>Vinyl Sliding Door</b></p> <p>Configuration: XO Glazing: Insulating Glass (Tempered)</p> <p>Frame: W-2426mm(95.50") H-2019mm(79.50")</p> <p>Panel: W-1229mm(48.38") H-1940mm(76.38")</p> <p>DLO: W-1111mm(43.75") H-1822mm(71.75")</p>

SPECIFICATION	PRODUCT RATING
<p><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b></p> <p><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b></p> <p><b>CSA A440S1-09</b></p>	<p><b>Class LC-PG40 2426 x 2019* (96 x 80*)-SD</b></p> <p><b>Design Pressure: ±1920 Pa (±40 psf)</b></p> <p>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</p> <p>Canadian Air Infiltration/Exfiltration Level: A3</p>

Product Tested By: Molimo, LLC  
 Report No: 2179.05-109-12  
 Expiration Date: **September 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023