

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016333.02  
DATE: 09/17/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Win-Curve  
CODE: 3079-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Win-Curve Windows, LLC</b> <b>2525 North Center Street</b> <b>Bonham, Texas 75418</b>	<b>Series "WCW 713-PDXO"</b> <b>Vinyl Sliding Door</b>  Configuration: XO Glazing: Insulating Glass (Tempered)  Frame: W-1816mm(71.50") H-2019mm(79.50") Panel: W-924mm(36.38") H-1940mm(76.38") DLO: W-806mm(31.75") H-1822mm(71.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG50 1816 x 2019* (72 x 80*)-SD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Molimo, LLC  
Report No: 2179.05-109-12  
Expiration Date: September 30, 2028

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023