

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016333.03
DATE: 09/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Win-Curve
CODE: 3079-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Win-Curve Windows, LLC 2525 North Center Street Bonham, Texas 75418	Series "WCW 713-PDXO" Vinyl Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1816mm(71.50") H-2019mm(79.50") Panel: W-921mm(36.25") H-1940mm(76.38") DLO: W-800mm(31.50") H-1819mm(71.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 1816 x 2019* (72 x 80*)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC
Report No: 3198.09-109-12
Expiration Date: September 30, 2028

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023