

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016333.04
DATE: 09/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Win-Curve
CODE: 3079-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Win-Curve Windows, LLC 2525 North Center Street Bonham, Texas 75418	Series "WCW 713-PDOXXO" Vinyl Sliding Door Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3620mm(142.50") H-2019mm(79.50") Panel: W-822mm(32.38") H-1943mm(76.50") DLO: W-806mm(31.75") H-1822mm(71.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG30 3620 x 2019 (143 x 80)-SD Design Pressure: 1440 Pa (30 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.60 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Molimo, LLC
Report No: 2498.07-109-12
Expiration Date: September 30, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023