

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016333.06
DATE: 09/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Win-Curve
CODE: 3079-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Win-Curve Windows, LLC 2525 North Center Street Bonham, Texas 75418	Series "WCW 713-PDOXO" Vinyl Sliding Door Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-2731mm(107.50") H-2019mm(79.50") Panel: W-940mm(37") H-1937mm(76.25") DLO: W-819mm(32.25") H-1822mm(71.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19 CSA A440S1-17	Class LC-PG50 2731 x 2019* (108 x 80*)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Molimo, LLC
Report No: 27792.04-109-12
Expiration Date: March 31, 2028

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023