

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016339  
DATE: 09/26/2024  
CERTIFICATION PROGRAM: Fire  
COMPANY: Carter Lumber  
CODE: 3091-1  
EXPIRATION DATE: 09/30/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Carter Lumber Corporation</b> <b>184 Pleasant Shade Drive</b> <b>Emporia, VA 23847</b>	<b>Steve's &amp; Sons/Crest Doors 6-Panel</b> <b>Embossed Steel Fire Door</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Single Maximum Size: 3'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>ASTM E152-81a</b> <b>UL 10B (1997)(2009)</b> <b>NFPA 252 (1999)</b>	<b>20 Minute-Neutral Pressure</b> <b>Without Hose Stream</b> <b>Category A - No Additional Edge Sealing</b> <b>System Required</b>

TEST REPORT
Intertek Test Report No: 3125633

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023