

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015860.02
DATE: 10/01/2024
CERTIFICATION PROGRAM: Structural
COMPANY: ABI Windows
CODE: 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ABI Windows, LLC 1121 Fulwiler Road Abilene, Texas 79603	Series "500" Vinyl Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1511mm(59.49") H-1207mm(47.52") Sash: W-730mm(28.74") H-1130mm(44.49") DLO: W-660mm(26") H-1064mm(41.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class R-PG50 1511 x 1207 (60 x 48)-HS Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Construction Consulting Laboratory
Report No: CCL 24-152
Expiration Date: **September 30, 2028**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com