

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015870.08  
**DATE:** 09/30/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ABI Windows  
**CODE:** 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ABI Windows, LLC</b> <b>1121 Fulwiler Road</b> <b>Abilene, Texas 79603</b>	<b>Series "500"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.50") H-2121mm(83.50") Sash: W-1130mm(44.50") H-1035mm(40.75") DLO: W-1111mm(43.75") H-978mm(38.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b>	<b>Class LC-PG50 1207 x 2121 (48 x 84)-H</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Construction Consulting Laboratory  
Report No: CCL 24-153  
Expiration Date: **September 30, 2028**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)