

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016394
DATE: 11/13/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
EXPIRATION DATE: 11/30/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	Composite Technology Internationalsl 20-Minute Fire-Rated (Without Hose) Single or Double Swing Wood Door Frame Manufacture Specific Fire Door Frames for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Single Maximum Size: 4'0" x 8'0" Double Maximum Size: 8'0" x 8'0" Minimum Thickness: 4-1/2"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008/2017) UL 10(c) (2009)	20 Minute-Positive Pressure Without Hose Stream

TEST REPORT
Intertek Test Report No: 100535906MID-004, 100535906MID-005 Intertek Engineering Evaluation: 100535906MID-006

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023