

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016400  
DATE: 11/18/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: OrePac  
CODE: 1234-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>OrePac Building Products</b> <b>30160 SW OrePac Avenue</b> <b>Wilsonville, OR 97070</b>	<b>Series "Builders Choice"</b> <b>Glazed Inswing Full Lite Steel</b> <b>Side Hinged Door</b> <b>(w/Internal Blinds)</b>  Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.50") H-2070mm(81.50") Panel: W-908mm(35.75") H-2007mm(79.00") DLO: W-530mm(20.88") H-1597mm(62.88")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-14</b> <b>ASTM E331-00</b>	<b>Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 0.00 Pa (0.00 psf)</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 06193900  
Expiration Date: October 31, 2028

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023