

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016406
DATE: 11/25/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Alvey Lumber
CODE: 2984-1
EXPIRATION DATE: 11/30/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	
Alvey Lumber Door Components, LLC 401 West 370 South Monroe, UT 84754	Therma Tru 20 Minute Fiberglass Door w/Proprietary Foam Core (Simulated, Flush or Shaker Panel Type) Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 36" x 96" Shaker Single Door Maximum Size: 36" x 80" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2016) NFPA 252 (2012)	20 Minute-without Hose Stream Positive Pressure Category B- Additional Edge Sealing Required
TEST REPORT	
Intertek Test Report No: 103875182MID-007	

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2024