

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016415
DATE: 11/25/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Alvey Lumber
CODE: 2984-1
EXPIRATION DATE: 11/30/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Alvey Lumber Door Components, LLC 401 West 370 South Monroe, UT 84754	Steve's & Sons/Crest Doors Flush Steel Skin Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2021)	20 Minute-Positive Pressure w/o Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 1055883406MID-004

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023