

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016441  
DATE: 12/17/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Hunan Greensee  
CODE: 3121-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Hunan Greensee Doors &amp; Windows Curtain Wall Co., Ltd. 10 Lantain N. Rd. Xingsha Ind. Base Changsha, Hunan, China 410137</b>	<b>Series "75P2 Inward Tilt-Turn" Aluminum Dual Action Window</b>  Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1800mm(70.87") Vent: W-1152mm(45.35") H-1752mm(68.98") DLO: W-1042mm(41.02") H-1642mm(64.65")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG30 1200 x 1800 (47 x 71)-DAW Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)</b>

Product Tested By: Intertek, Inc.  
Report No: 240325094GZC-002  
Expiration Date: **July 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)