

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016443  
DATE: 12/18/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Anhui Guo Jian  
CODE: 3111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Anhui Guo Jian Door & Window Curtain Wall Engineering Co., Ltd Shouxian County Xinqiao Int. Ind. Park Pioneer Park, Anhui, China	Series "105" Vinyl Double Hung Window  Configuration: X/X Glazing: Insulating Glass (Tempered) Frame: W-1100mm(43.31") H-1900mm(74.80") Sash: W-1030mm(40.55") H-922mm(36.30") DLO: W-986mm(38.82") H-877mm(34.53")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class R-PG15 1100 x 1900 (43 x 75)-H Design Pressure: $\pm 720$ Pa ( $\pm 15$ psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: Intertek, Inc  
Report No: 221228001SHF-001  
Expiration Date: July 31, 2028

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023