

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016445
DATE: 12/18/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Anhui Guo Jian
CODE: 3111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Anhui Guo Jian Door & Window Curtain Wall Engineering Co., Ltd Shouxian County Xinqiao Int. Ind. Park Pioneer Park, Anhui, China	Series "82" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Tempered) Frame: W-1100mm(43.31") H-1900mm(74.80") Sash: W-1048mm(41.26") H-932mm(36.69") DLO: W-990mm(38.98") H-876mm(34.49")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class R-PG15 1100 x 1900 (43 x 75)-H Design Pressure: ±720 Pa (±15 psf) Water Penetration Resistance Test Pressure: 140 Pa (2.92 psf)

Product Tested By: Intertek, Inc
Report No: 221228001SHF-003
Expiration Date: **July 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023