

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016451
DATE: 01/06/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Ongoing
CODE: 3122-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ongoing Further Group, LLC 8605 Santa Monica Boulevard #79525 West Hollywood, CA 90069	Series "69" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1500mm(59.06") H-1500mm(59.06") DLO: W-1390mm(54.72") H-1390mm(54.72")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG60 1500 x 1500 (59 x 59)-FW Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC
Report No: 240812011SHF-001
Expiration Date: August 31, 2028

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com