

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016458
DATE: 01/06/2025
CERTIFICATION PROGRAM: Structural
COMPANY: SLEEK
CODE: 3114-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
SLEEK (Shanghai) Intelligent System Co., Ltd. No. 61, Lane 2329, Jiasong Middle Road, Qingpu District, Shanghai, China 310118	Series "SLEEK 83" Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-800mm(31.50") H-1500mm(59.06") Vent: W-761mm(29.97") H-1461mm(57.53") DLO: W-682mm(26.84") H-1382mm(54.40")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG50 800 x 1500 (32 x 59)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: 240924012SHF-004
Expiration Date: November 30, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com