NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016459.01-R1**
DATE:	**01/08/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Therma-Tru**
CODE:	**052-1**
REVISION DATE:	**02/04/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation **118 Industrial Drive** **Edgerton, OH 43517**	**"Impact-Rated Opaque Fiberglass Side-Hinged Door Assembly w/Composite Jamb Sidelite Sills"** **(w/ Sidelites)** Configuration: OXO Glazing: IG-1/8" Tempered Glass/5/32" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1816mm(71.5") H-2470mm(97.25") Panel: W-911mm(35.88") H-2419mm(95.25") DLO: W-175mm(6.88") H-2004mm(78.88")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 **ASTM E330-14** **ASTM E331-00** **ASTM E1886-19/ASTM E1996-20** **TAS 210/202/203-94**	**Design Pressure: ±2394 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)** **Wind Zone 4 - Missile Level D** **Large Missile Impact Rated**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01463913A/TEL 01463913
Expiration Date: **November 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com