NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016365.01
DATE: 03/31/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Vistamark
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vistamark Enterprises, LLC **3581 S. Hwy 287** **Waxahachie, TX 75165**	**Series "Endura 201"** **Vinyl Fixed Window** Configuration: O Glazing: IG-Ext. 5/32" Annealed Glass/1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass Frame: W-1524mm(60") H-1524mm(60") DLO: W-1422mm(56") H-1422mm(56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class LC-PG50 1524 x 1524 (60 x 60)-FW** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Molimo, LLC
Report No: 29999.02-109-12
Expiration Date: **February 28, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com